



ASSOCIAZIONE PER LA CERTIFICAZIONE
DELLE APPARECCHIATURE ELETTRICHE

Tito Livio, 5 - 24123 - BERGAMO (Italy)
+390354175244 fax. +390354534662 e-mail:acaecert@tin.it



Certificate of Conformity

LOVAG-Certificate No. **IT 12.071**

Apparatus

Three phases low voltage switchgear 415 V (U_n/U_e) - 690 V (U_i) -
8 kV (U_{imp}) - 15 kA x 1 sec. (I_{cw}) 25 kA x 1 sec. (I_{cw}) - 50 Hz - 400 (I_nA)

Designation

XL³ 400 - VX³ 400 Arrangement 69

Manufacturer or responsible vendor

Legrand S.n.c. -128, Av.du Maréchal-de-Lattre-de-Tassigny-
87045 Limoges Cedex (France)

Tested for: Legrand S.n.c.

Tested by: ACAE Laboratory IB01

The apparatus, constructed in accordance with the description mentioned in the Test Report listed on this Certificate has been subjected to the series of proving tests in accordance with IEC 61439-2 Ed.2.0 (2011-8)- EN 61439-2:2011.

10.11 Short circuit withstand strength

The results are shown in the Test Report in accordance to LOVAG. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the characteristics assigned by the manufacturer as stated below.

Icw 15 kA for 1 second and 25 kA for 0,5 second

This document includes: Test Report No.: 12.132
Issue date : 2012.10.11

Responsible Certification Body : ACAE
Mauro Marchi

Authorized signature

Date: 2012.10.29



PRD N°070B
Signatory of EA, IAF and ILAC
Mutual Recognition Agreements

This certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designation with that tested rests with the manufacturer or responsible vendor.

This certificate has been prepared according to LOVAG (Low Voltage Agreement Group) Objectives and Operating Principles of mutual recognition.

The responsible certification body as member of LOVAG issues a Certificate of Conformity with the above mentioned Standard(s) following the exclusive use of LOVAG Test Instructions wherever applicable.

Only integral reproduction of this Certificate or reproductions of this page accompanied by any page(s) on which are stated the tests performed and the assigned rated characteristics of the apparatus Tested, are permitted without written permission from the LOVAG Laboratory responsible for this Certificate.

Expiry of this certificate is the ACAE certification scheme.