



ASSOCIAZIONE PER LA CERTIFICAZIONE
DELLE APPARECCHIATURE ELETTRICHE

Via Tito Livio, 5 - 24123 - BERGAMO (Italy)
Tel. +390354175244 fax. +390354534662 e-mail:acaecert@tin.it



Certificate of Conformity

LOVAG-Certificate No. IT 12.070

Apparatus

Three phases low voltage switchgear 415 V (U_n/U_e) - 690 V (U_i) -
8 kV (U_{imp}) - 15 kA (I_{cw}) - 50 Hz - 250 A (I_{nA})

Designation

XL³ 400 - VX³ 250 Arrangement 68

Manufacturer or responsible vendor

Legrand S.n.c. -128, Av.du Maréchal-de-Lattre-de-Tassigny-
87045 Limoges Cedex (France)

Tested for: Legrand S.n.c.

Tested by: ACAE Laboratory IB01

The apparatus, constructed in accordance with the description mentioned in
the Test Report listed on this Certificate has been subjected to the series of
proving tests in accordance with IEC 61439-2 Ed.2.0 (2011-8)-
EN 61439-2:2011.

10.11 Short circuit withstand strength

The results are shown in the Test Report in accordance to LOVAG. The
values obtained and the general performance are considered to comply with
the above Standard(s) and to justify the characteristics assigned by the
manufacturer as stated below.

Icw 15 kA for 1 second

This document includes: Test Report No.: 12.131

Issue date : 2012.10.11

Responsible Certification Body : ACAE
Mauro Marchi

Authorized signature

Date: 2012.10.29



PRD N°070B
Signatory of EA, IAF and ILAC
Mutual Recognition Agreements