



ASSOCIAZIONE PER LA CERTIFICAZIONE  
DELLE APPARECCHIATURE ELETTRICHE

Tito Livio, 5 – 24123 – BERGAMO (Italy)  
+390354175244 fax. +390354534662 e-mail:acaecert@tin.it



# Certificate of Conformity

LOVAG-Certificate No. IT 12.073

## Apparatus

Three phases low voltage switchgear 415V ( $U_n/U_e$ ) – 690V ( $U_i$ ) – 8kV ( $U_{imp}$ )  
– 50kA ( $I_{cw}$ ) – 50Hz – 800A ( $I_{nA}$ )

## Designation

**XL<sup>3</sup> 800 - VX<sup>3</sup> 800 Arrangement 70**

## Manufacturer or responsible vendor

**Legrand S.n.c.** – 128, Av. du Maréchal-de-Lattre-de-Tassigny  
87045 Limoges Cedex (France)

## Tested for: Legrand S.n.c.

**Tested by: ACAE Laboratory IB 01**

The apparatus, constructed in accordance with the description mentioned in the Test Report listed on this Certificate has been subjected to the series of proving tests in accordance with IEC 61439-2 Ed.2.0 (2011-8) EN 61439-2:2011.

### 10.11 Short circuit withstand strength

The results are shown in the Test Report in accordance to LOVAG. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the characteristics assigned by the manufacturer as stated below:

$I_{cw}$  50kA for 0,5 seconds

This document includes Test report No. : 12.134

Issue date: 2012.10.11

Responsible Certification Body : ACAE  
Mauro Marchi



Authorized signature

Date: 2012.10.29



**PRD N°070B**  
Signatory of EA, IAF and ILAC  
Mutual Recognition Agreements